

Critical Overview of Lightning Risk Assessment from IEC and NFPA Perspectives

(Implications of the IEC 62305-2:2024 Update and a Hybrid Practice Framework)

Shriram Sharma, PhD

South Asian Lightning Network; Aegisflash Solutions

Abstract

Lightning protection system (LPS) design increasingly relies on formal risk assessment, yet many practitioners find existing standards complex, data-intensive, or difficult to translate into clear investment decisions. IEC 62305-2:2024 provides a rigorous quantitative framework, while NFPA-780 offers prescriptive, legally defensible implementation guidance, but each standard reflects different regulatory philosophies and practical limitations. The 2024 revision of IEC 62305-2 introduces major refinements, including a unified risk concept, explicit treatment of damage frequency, adoption of lightning ground strike-point density, and formal recognition of thunderstorm warning systems (TWS). These changes strengthen analytical capability but also sharpen questions about data quality, parameter sensitivity, and usability in data-sparse regions. By contrast, NFPA-780 continues to emphasize a consequence-oriented, prescriptive design philosophy aligned with North American legal and insurance expectations, but it offers limited support for explicit cost-benefit optimization or risk-differentiated prioritization. This article provides a critical, practice-focused synthesis of both standards. It highlights key strengths and limitations from a practitioner's viewpoint and proposes a hybrid four-step workflow that uses IEC 62305-2:2024 for quantitative screening and economic evaluation while relying on NFPA-780 for robust implementation. The combined approach aims to enable technically sound, economically rational, and clearly communicable lightning protection decisions.

1. Introduction

Lightning is one of the leading natural causes of weather-related human fatalities and a significant source of damage to buildings, infrastructure, and electrical systems worldwide. However, it is still systematically underrated in disaster risk reduction, infrastructure planning, and public-safety

policy, particularly in developing nations. Unlike earthquakes, cyclones, or floods, lightning fatalities tend to be dispersed, underreported, and normalized as isolated incidents rather than recognized as manifestations of a persistent, preventable hazard. As a result, lightning-related deaths and injuries continue at alarming levels despite mature engineering standards and proven protection technologies.

This under-recognition is not confined to developing countries but even in developed nations, lightning protection is frequently installed reactively, after damage, outages, or insurance claims, rather than proactively, based on documented risk. The absence of formal risk assessment leads to inconsistent protection levels, retrofit-driven upgrades, inspection disputes, and difficulties in justifying investment decisions to non-technical stakeholders.

For practitioners, the key issue is no longer the technical validity of lightning risk assessment, but whether its outcomes effectively inform LPS design decisions and asset management strategies. IEC 62305-2 and NFPA-780 offer complementary approaches: the IEC framework explains why protection is required and to what extent, while NFPA-780 provides practical guidance on how systems should be designed, installed, inspected, and maintained. Bridging these perspectives is crucial not only for enhancing infrastructure resilience but also for minimizing avoidable losses of life and property.

2. IEC 62305-2:2024 - Key features and limitations for practitioners

The 2024 revision of IEC 62305-2 brings several important updates for practitioners. One key change is the introduction of a unified risk approach that combines the risk to human life and the risk of physical damage into a single measure. This makes it easier for engineers to communicate lightning risk in terms that are familiar to asset managers and insurers, such as expected annual losses and frequency of damage rather than relying on abstract probability values. The revised standard also places greater emphasis on damage to internal systems, acknowledging that in modern facilities, service interruptions and downtime often account for a significant share of total losses.

Another significant development is the replacement of ground flash density with lightning ground strike-point density, better representing the physical interaction between lightning and structures. These updates enhance the physical realism of the model and reduce uncertainty in selecting regional lightning data, especially where high-resolution detection networks are available. The formal inclusion of thunderstorm warning systems (TWS) as preventive risk-reduction measures also

strengthens the link between engineering design and operational risk management, reflecting their increasing use in critical facilities. Collectively, these improvements make IEC 62305-2 a more practical and defensible decision-making tool, rather than merely a theoretical calculation framework.

2.1 Practical limitations and uncertainties

Despite its strengths, several practical limitations should be recognized:

- i. Data dependence and parameter sensitivity: IEC 62305-2 relies on detailed inputs such as strike-point density, exposure characteristics, environmental factors, and damage probabilities. In regions with limited lightning monitoring or loss data, these inputs are often estimated using generic values, which can significantly increase uncertainty in the calculated annual risk.
- ii. Complexity and usability: Even with the 2024 updates, the methodology remains complex for occasional users. Misinterpretation of loss categories, incorrect assignment of coefficients, or inconsistent treatment of internal system risks can lead to unreliable outcomes.
- iii. Conservatism versus risk differentiation: The use of conservative default values to address data gaps may cause different structures to yield similar risk estimates, reducing the ability to effectively prioritize protection measures across assets.
- iv. Limited contextual guidance on tolerable risk: While the standard defines tolerable risk thresholds, it offers limited direction on aligning these with local regulations, organizational risk tolerance, or insurance requirements, often leaving practitioners to determine acceptable levels case by case.

Recognizing these limitations is essential to avoid overreliance on calculated metrics and to ensure transparent communication of assumptions and uncertainties when applying IEC-based risk assessments for decision-making.

3. NFPA-780: Prescriptive and consequence-oriented practice

NFPA-780 adopts a complementary approach by focusing on consequence-based decision-making and clear, prescriptive construction rules rather than a universal probabilistic risk model. Protection requirements are determined based on factors such as occupancy, structure type, exposure, and the severity of potential consequences, with well-defined criteria for when and how a lightning protection system (LPS) should be installed. This approach aligns closely with legal and insurance

practices in North America and offers the practical advantage of being straightforward to interpret, inspect, and enforce.

The standard places strong emphasis on construction quality, proper bonding and grounding, and ongoing maintenance. This reflects practical experience showing that many lightning protection failures result not from flaws in analysis, but from poor installation or inadequate upkeep. As a result, NFPA 780 effectively establishes a “standard of care” for implementation, meaning that systems designed and installed in accordance with its requirements are generally regarded as technically sound, compliant, and insurable.

3.1 Strengths and limitations

Key strengths include:

- i. Clear, checklist-friendly design and inspection criteria.
- ii. Strong linkage to building codes, insurance requirements, and legal precedent in North America.
- iii. Focus on workmanship, inspection, and lifecycle maintenance.

However, there are important limitations:

- i. Lack of explicit quantitative optimization: NFPA 780 provides limited guidance for explicit cost-benefit analysis or portfolio-level prioritization. All structures meeting prescriptive triggers may be treated similarly, regardless of differences in asset value or service criticality.
- ii. Potential for uniform conservatism or under-protection: Prescriptive triggers may lead to over-protection of some low-consequence structures and under-protection of critical assets that narrowly fall outside trigger definitions, especially when local adoption or enforcement is uneven.
- iii. Limited integration of operational measures: While NFPA-780 acknowledges surge protection and bonding, it does not yet provide a comprehensive framework for integrating TWS or other operational risk-reduction measures into design justifications.

These limitations underscore the value of augmenting NFPA-780 with a structured risk-assessment framework such as IEC 62305-2:2024.

4. Why practitioners should adopt risk-assessment results in LPS design

Risk assessment should not be adopted as an alternative to prescriptive design but as a means of strengthening and targeting it. IEC-based risk assessment adds practical value in several ways:

- i. Justification of investment: Quantified annual expected loss provides a rational basis for explaining why lightning protection is needed and why a specific protection level is appropriate for a given asset.
- ii. Prioritization across assets: Comparable risk metrics enable portfolio-level ranking of buildings and infrastructure, supporting phased implementation strategies rather than ad-hoc decisions driven by recent incidents or individual preferences.
- iii. Optimization of protection measures: Risk results reveal whether external LPS, internal surge protection, bonding improvements, TWS deployment, or operational measures deliver the greatest marginal benefit, allowing more efficient allocation of limited budgets.
- iv. Improved stakeholder communication: Translating lightning risk into economic and service-continuity terms improves engagement with owners, insurers, and regulators, who frequently think in terms of expected annual cost and service downtime rather than physical metrics.
- v. Defensibility and documentation: A documented risk assessment demonstrates due diligence, reducing professional and organizational liability and supporting audits, inspections, and insurance negotiations.
- vi. Integration with NFPA-compliant design: When mapped into NFPA-780 installations, risk-assessment results cease to be abstract numbers and become concrete engineering decisions about protection levels, layout choices, and lifecycle upgrades.

5. A hybrid IEC-NFPA workflow for practical implementation

Comparison of IEC 62305 and NFPA-780 indicates that neither standard, considered independently, sufficiently meets the requirements of practitioners working under widely varying hazard conditions and regulatory frameworks. IEC 62305-2 excels as a diagnostic and ranking tool for portfolios of assets but can be challenging where input data are uncertain or where users are unfamiliar with probabilistic methods. NFPA-780 embodies a robust “standard of care” with strong insurance and legal alignment, particularly in North America, yet it does not inherently support economic optimization or risk-differentiated prioritization.

The objective of this article is pragmatic rather than purely theoretical. It proposes a hybrid workflow that springs from the revised IEC 62305-2 framework yet remains simple enough to be routinely applied and clearly communicated, while leveraging NFPA-780 as a practical execution and enforcement standard. The four overarching steps are:

- i. IEC-based screening and risk ranking.
- ii. Translation of identified measures into NFPA -780 design actions.
- iii. Quantitative cost-benefit comparison using annual expected loss.
- iv. Documentation and lifecycle management.




Figure 1. Hybrid IEC–NFPA Lightning Risk Management Workflow

5.1 Workflow description

Figure 1 presents a high-level flowchart of the hybrid IEC-NFPA Lightning Risk Management Workflow. Its key stages include:

- i. Project definition and boundary conditions: Define structure type, occupancy, location, lightning density, service lines, and criticality. NFPA-780 establishes minimum triggers, while IEC 62305-2 defines loss categories and risk logic.

- ii. Preliminary screening: Apply NFPA-780 triggers such as structure height, hazardous materials, public assembly, or mission-critical use. If triggers apply, lightning protection is mandatory; otherwise, IEC screening helps decide whether formal analysis is warranted.
- iii. Quantitative risk assessment: Use IEC 62305-2 to compute risk components (R1-R4) based on strike-point density, exposure, occupancy, and loss factors, explicitly including internal system and service-continuity impacts where relevant.
- iv. Protection level mapping: Translate IEC Lightning Protection Levels (LPL I-IV) into NFPA-compliant geometries and layouts, selecting appropriate air terminals, down conductors, and earth terminations.
- v. External lightning protection system: Design air terminals, down conductors, and earth termination systems using NFPA-780 construction rules that are consistent with the IEC protection assumptions.
- vi. Internal LPS and surge protection: Apply IEC Lightning Protection Zones (LPZ) to identify interface points and coordinate surge protective devices (SPDs) of Types 1, 2, and 3 in accordance with NFPA enforcement and equipment requirements.
- vii. Cost-benefit analysis: Compare expected annual loss before and after protection against installation and lifecycle costs to justify the selected protection level, acknowledging uncertainties in both risk and cost estimates.
- viii. Optimization loop: Iteratively adjust LPL, SPD coordination, and grounding resistance to minimize residual risk or total cost while maintaining NFPA compliance.
- ix. Compliance and documentation: Prepare IEC risk reports, NFPA drawings, bills of quantities, inspection plans, and compliance documentation, ensuring traceability from risk metrics to physical details.
- x. Tool and service deployment: Automate risk calculations, design outputs, and cost-risk trade-offs through software tools or Software as a Service (SaaS) platform, making the methodology accessible in regions lacking specialist consultants.

This workflow positions IEC 62305-2:2024 as a diagnostic and economic evaluation engine while using NFPA-780 as the implementation backbone.

6. Illustrative application: Hospital facility

Application of the hybrid workflow to a representative hospital highlights several practical insights. IEC-based analysis typically reveals that internal system failures and service continuity dominate risk components, reflecting the high cost of downtime and equipment damage in healthcare

facilities. When candidate protection packages are evaluated, coordinated SPDs, enhanced bonding, and an external LPS together provide substantial reductions in both risk and damage frequency with a payback period that is acceptable relative to the facility's operational lifetime.

In this context, NFPA-780 is used to translate the chosen protection package into detailed design and inspection requirements: air-termination layouts, down-conductor routing, earth-termination configurations, SPD locations, bonding details, and maintenance plans. The case study underscores how risk assessment can justify higher-grade protection in critical zones (e.g., imaging suites, intensive care units) while allowing more modest measures in lower-criticality areas, thereby reconciling clinical priorities, budget constraints, and code compliance.

7. Recommendations for practice, policy, and tools

Widespread adoption of lightning risk assessment requires more than technical accuracy. The following strategies are essential for global uptake of the hybrid approach:

- i. Tool usability: Risk tools should present complex calculations behind intuitive interfaces, focusing practitioner attention on inputs they can reliably provide and outputs they can readily interpret.
- ii. Direct linkage to NFPA -780 and local codes: Risk-assessment outputs should directly reference NFPA-780 clauses, drawings, and bill-of-quantity items or equivalent national codes reinforcing continuity between analysis and construction.
- iii. Education and certification: Incorporating risk-based decision-making into certification programs, continuing education, and inspector training demystifies the methodology and builds confidence.
- iv. Demonstrating business value: Showing that documented risk assessment supports premium reduction, compliance audits, and loss prevention encourages owner-driven demand for rigorous lightning protection.
- v. Scalable digital solutions: Cloud-based tools that automate data inputs, generate standardized reports, and track residual risk over time can scale expert knowledge to regions lacking specialist consultants and detailed lightning data.

8. Conclusions

IEC 62305-2:2024 and NFPA-780 represent two complementary perspectives on lightning risk: one quantitative and risk-based, the other consequence-oriented and prescriptive. The revised IEC document strengthens the risk framework through a unified risk concept, explicit frequency-of-damage treatment, updated exposure modelling using ground strike-point density, and

formal recognition of preventive operational measures such as thunderstorm warning systems. Nevertheless, it remains complex and data-dependent without simplification and careful integration into everyday practice. NFPA-780 provides a straightforward, legally and commercially familiar approach but lacks built-in mechanisms for quantitative cost-benefit evaluation and portfolio-level prioritization.

The hybrid approach proposed here enables practitioners to move beyond an artificial choice between standards and instead combine their strengths to support protection that is technically robust, economically rational, and clearly communicable. By coupling IEC-based risk metrics and cost-benefit insights with NFPA-style prescriptive design and inspection, practitioners can answer critical questions about how much protection is justified, what it will cost, and what risk reduction is achieved in a defensible and transparent way.

Adopting such a hybrid framework can help elevate lightning from an underestimated hazard to one that is systematically addressed within modern safety engineering and asset-management practice, particularly in regions where exposure is high, resources are constrained, and the consequences of failure are severe.

References

1. IEC 62305-2:2024. Protection against lightning - Part 2: Risk management. International Electrotechnical Commission.
2. IEC 62305-3:2024. Protection against lightning - Part 3: Physical damage to structures and life hazard.
3. IEC 62305-4:2024. Protection against lightning - Part 4: Electrical and electronic systems within structures.
4. IEC 62793:2020. Protection against lightning - Thunderstorm warning systems.
5. NFPA 780:2023. Standard for the Installation of Lightning Protection Systems. National Fire Protection Association.
6. Rakov, V. A., & Uman, M. A. (2003). Lightning: Physics and Effects. Cambridge University Press.